

Client: DIXON SAND (PENRITH) PTY LTD  
PO BOX 148  
PENRITH NSW 2751

Job No: 7555/1  
Date: 20/09/2019  
Tested By: SS  
Checked By: AK

Project: MATERIAL ANALYSIS  
MATERIAL TESTING - 4610 OLD NORTHERN ROAD, MAROOTA

## TEST RESULTS

Page 1 of 1

| TEST PROCEDURE AS1141.11.1 (DRY SIEVING), 12 |  |   |  |
|--|--|---|--|
| Material Description                         | Bricklaying SAND (White)                               |   |  |
| Sieve Analysis                               |  |   |  |
| Laboratory Number                            | 7555/1-346   |   |  |
| <u>Sieve Size</u>                            | Percentage Passing                                     | Pre-treatment<br>Nil - Standard Oven Drying   |  |
| 9.5mm  | 100  | <div style="border: 1px solid black; padding: 5px;"> <p><b>AS1141.12 Materials finer than 75 microns in Aggregates (by washing) % Passing</b></p> <hr/> <p style="text-align: center; font-size: 1.2em;"><b>10.3</b></p> </div> |  |
| 4.75mm                                       | 100  |   |  |
| 2.36mm                                       | 95   |   |  |
| 1.18mm                                       | 73   |   |  |
| 600 microns                                  | 41   |   |  |
| 300 microns                                  | 10   |   |  |
| 150 microns                                  | 2  |   |  |
| 75 microns                                   | 0.7  |   |  |
| Date Sampled                                 | 05/07/2019   |   |  |
| Sampling Procedure                           | Sampled by Client. Results apply to sample as received |   |  |
| Sampling Location                            | Ex Maroota Quarry                                      |   |  |

Form No: R 025 Version 05/06/13 - issued by ER



Nata Accreditation Number 2734  
Corporate Site Number 2727

Accredited for compliance with ISO/IEC 17025.

A Kench 20/09/2019

Approved Signatory



Head Office:  
34 Borec Road, Penrith NSW 2750  
P O Box 880 Penrith NSW 2751  
Telephone: (02) 4722 2744 Facsimile: (02) 4722 2777

Prestons Laboratory:  
Unit 4, 18-20 Whyalla Place, Prestons NSW 2170  
Telephone: (02) 9607 6111 Facsimile: (02) 9607 6200

email: info@geotech.com.au www.geotech.com.au